

# Haiphong City in Vietnam Waste to Energy Project



**December 24, 2017** 

HANVIT Power Inc.

**M** Korea District Heating Engineering Co., LTD.

Woowin Keytek Co., LTD.

### **Agenda**

### 1. Technology

<ul><li>Project Overview</li></ul>	4~14
<ul><li>Process Concept</li></ul>	15~23
<ul> <li>Reference Plant</li> </ul>	24~45
<ul> <li>Project Execution Strategy</li> </ul>	46~60
<ul> <li>Financial Analysis</li> </ul>	61~64

#### 2. Addition Discussion

<ul><li>Pre-Treatment Process</li></ul>	66~69
<ul> <li>Organic Material Treatment</li> </ul>	70~74
Plant Area	75~76

#### 3. Institutional Capability and Financial Statement

◆ Hanvit Power◆ KDHEC78~8586~96







# 1. Technology







# **Project Overview**





### **Project Overview**

Project : Haiphong City Waste to Energy Project

Client : Haiphong City, Vietnam

■ Location : KCN Đình Vũ Đông Hải, Hải An, Hải Phòng, Việt Nam

(N 20.827184, E 106.768315)

Capacity : 23.3 Mwe/hour

■ PPA : USD 9.5 cents/kwh

Contract : HANVIT Power Consortium

5


Duration : 35 Months





### **MSW Plant Site**

KCN Đình Vũ Đông Hải, Hải An, Hải Phòng, Việt Nam










### **Dinh Vu Industrial Park**









### **MSW Plant Site**

KCN Đình Vũ Đông Hải









### Municipal Solid Waste in Hai Phong City

#### Opening/closing of landfill sites :

 Almost 90% of landfill sites have been built within 20 years; many of the sites just closed or will be closing very soon (because of long-lasting effect to the water source and bad smell to the air)

#### Disposal completion rate of landfill:

• Over 50% of landfill area are filled with more than 80% of the total.

#### Population/waste volume

- Over 80% of URENCOs cover less than 400,000 people, and about 60% of URENCOs collect less than 50,000 ton of waste per year.
- Till 2016, total population of Hai Phong City is 1.963 million people. Hai Phong Urencos has collected about 80% of total urban solid wastes, and accounting for 60% of total solid wastes generated by Hai Phong people yearly

#### Waste composition:

 Average composition of highly organic waste is 72.6%. (55,18~57,60%- data from Jica, Mar 2011)

#### Collection fee:

- URENCOs collect on average 14,100 VND/month/household (70US cent) as the waste collection fee.
- At present, 1 household in Haiphong City has to pay 40,000 VND (1.76\$)/month to URENCOs for collection, trans.port and disposal. Factory, office, hotel, restaurant, hospital, school has to pay 324,000 vnd(13,6\$)/month (QD:3257/2016/QD-UBND dated 22/12/2016

Ref: MRV designed for NAMAs in Waste Sector in Vietnam, Presented by: Anh Tien Do, Ph.D., Vietnam Institute of Meteorology, Hydrology and Environment







### **Composition of MSW**

Table 5. Composition of solid waste in Vietnam's cities in 1998 - % in weight

Composition	Hanoi	Haiphong	Halong	Danang	Ho Chi Minh City
Organic compounds	50.1	50.6	40.1- 44.7	31.5	41.3
Plastic, rubber, leather	5.5	4.5	2.7 - 4.5	22.5	8.8
Paper in all kinds	4.2	7.5	5.5 - 5.7	6.8	24.8
Metal	2.5	0.2	0.3 - 0.5	1.4	1.6
Brick, stone, ceramics	1.8	0.6	3.9 - 8.5	1.8	5.6
Soil, cobble & other solids	35.9	36.5	47.5 - 36.1	36	18
Water content	47.7	45 - 48	40- 46	39.1	27.2
Ash content	15.9	16.6	11	40.3	58.8
Density, ton/m <sup>3</sup>	0.42	0.45	0.57-0.65	0.38	0.412

Source: Report "State of Environment in Vietnam 2001" - NEA

Woods: 3.7%

Ref: Solid Waste Management in Vietnam, An Industrial Ecology Study by Thao Nguyen School of International and Public Affairs, Columbia University Adviser: Prof. Nickolas J. Themelis, Earth and Environmental Engineering







### **Heat Value for MSW Haiphong**

#### We assume MSW Heat Value data for Haiphong City

 We get a data from Dhaka(Bangladesh) and South Tangerang (Indonesia) with similar living culture

#### Reference Report

- Prospect of Electric Energy from Solid Wastes of Rajshahi City Corporation: A Metropolitan City in Bangladesh; IPCBEE vol.17 (2011) © (2011) IACSIT Press, Singapore
  - Average Value for Dhaka and Chittagong city: 7.38 MJ/kg -> 1,763 Kcal/kg
  - Rajshahi City is 7.94 MJ/kg -> 1897 Kcal/kg
  - Average Value above two city: 7.66 MJ/kg -> 1,829,87 Kcal/kg
- Feasibility Study & Basic Design Report for South Tangerang, 2015.12
  - Standard Quality: 1,800 Kcal/kg
- Assumed Calorific Value in Hai phong: 1,800 Kcal/kg







### **Heat Value & Power Generation**

#### Design Criteria for Calorific Value

Waste Receive : 2,000 t/d (Pre-Treatment Process) -> 1,000 t/d to Fuel

Calorific value: 1,800 kcal/kg (Pre-Treatment Process) -> 2,400kcal/kg

#### Power Generation Simulation

No.	Item	Value	Unit	Remark
1	MSW Receive	2,000	Ton/day	
2	After Sorting	50.0%		
3	MSW Fuel	1,000	Ton/day	
4	MSW Calorific Value	2,400	Kcal/kg	
5	Boiler Efficiency (CFBC Type)	25%		
6	Power Generation (Gross)	29.070	Mwe/hr	
7	Internal Use	20.0%		5,814 KWe
8	Power Generation (Net)	23.256	Mwe/hr	
9	Remaining Ash	48	Ton/day	< 5%


It is strongly recommend to burn additional fuel to increase heat value for higher power generation output.







### **Noncombustible Ash Release**









### **Ash Quantity and Treatment**

#### Emission Quantity

● Ash: 2,000 Kg/h x 24 -> **48 tpd (<5%)** 

• Flue Gas: 300 Kg/h

#### Composition of Ash

- Incombustible Component (Most)
  - Ca, Mg, Si(silica) Al, Fe
- Chemistry Component (Extremely small quantities)
  - Hg, Cd, Pb, As, Cr

#### Chemistry Component

- Chemistry Component will be landfilled with others
- This Chemistry was originally existed in Nature and no harmful too extremely small quantity

Ref: Naju Project Design Data







# **Technology and Process** Concept





### **Electrical Power Generation**

ltem	Value	Remark
Steam turbine – gross power output	29.070 MWe/h	
Internal Use	5.814 MWe/h	
Steam turbine – net power output	23.256 MWe/h	
Exhaust steam pressure	Approx. 0,12 bar(a)	
Yearly Average Temperature	30°C	





### **Comparison Grate & FBC Type**


Item	Grate type	FBC type (Our Technology)
Features		
Technical feature	<ul> <li>Mass burning on the moving grate</li> <li>Drying, combustion, after-combustion process</li> <li>No need of Pretreatment</li> </ul>	<ul> <li>Fluidized Bed Combustion</li> <li>Fuel flexibility (mixed fuel firing)</li> <li>Low emissions</li> <li>Mechanical Pretreatment Required</li> </ul>
Furnace Temp	950~1050°C	850~950°C
Useable Fuel	<ul><li>Bulk MSW</li><li>1000~3500 kcal/kg</li></ul>	<ul> <li>Coal, SRF(RDF), Biomass(Wood chip), etc.</li> <li>1600~8000 kcal/kg</li> </ul>
Flue gas quantity	100	88 (based on Grate type 100)
Plant Efficiency	10~15%	20~25%
<b>Construction Cost</b>	200,000 USD/ton	220,000~250,000 USD/ton
Operation Cost	60 USD/ton	100 USD/ton








# Circulating Fluidized Bed Combustor (CFBC)





HANVIT Power Inc.

### **Environment Facility for CFBC**









### **Air Pollutant Emission Standard**

No.	Contamination	Unit	Government Regulation	Korea Regulation	Remark
1	HCI	mg/Nm3	50	15	
2	SO <sub>2</sub>	mg/Nm3	250	50	
3	NO <sub>2</sub>	mg/Nm3	500	50	
4	со	mg/Nm3	250	50	
5	Hg	mg/Nm3	0.2	0.03	
6	Cd	mg/Nm3	0.16	0.02	
7	Pb	mg/Nm3	1.2	0.2	
8	Dioxin	(ng-TEQ/Nm3)	0.6	0.1	

Ref: Circular No. 03/2016/TT-BTNMT; March 3, 2016







# **De-Dust System**

	Bag Filter	Ceramic Candle Filter	Wet Scrubber
Picture	Double Disphragm Valve  Pulse Header  Clean Air Plenum Pulse Manifold Pipe  Clean Floor Design  Filter Bags  Dust Discharge  Inlet With Gas Distribution Baffle		Cleaned air  Mist elimination mesh pad  Mesh pad cleaning water header  Reagent introduction header  Packing Support grate  Smog (Soot)  Circulation Reagent
Features	<ul> <li>Effective for removal of solid granules such as dust</li> <li>Periodic maintenance necessity such as replacement of bag</li> <li>Pulsation phenomenon due to purge</li> <li>Additional removal effect by fabric surface cake of chemical reagent</li> </ul>	Effective for removal of solid granules     Limitations on particulate removal     High cost	<ul> <li>Reduction effect of solid granular removal and harmful substance</li> <li>Relatively low cost</li> <li>Depending on the target to be removed, chemicals and water are required. Wastewater is generated.</li> </ul>
Selection	Our Technology		







# **Acid Gas**

	Wet Scrubber	SDR(Semi-dry Reactor)	Dry Reactor
Picture	Mist elimination mesh pad cleaning water header  Reagent introduction header  Smog (Soot)  Circulation Reagent	Lime Water Fly Ash	Flue 6as Fly Ash
Features	<ul> <li>Exhaust flue gas passes through the chemical solution</li> <li>High removal efficiency due to direct contact between liquid and gas phase</li> <li>High initial investment cost</li> <li>Wastewater is generated and waste water treatment is required.</li> </ul>	Dissolve the absorbent in water and inject it into the exhaust flue gas through a spray device     Relatively low initial investment cost     Waste generation increase     Relatively low efficiency     High O&M cost	<ul> <li>Powdered absorbent is added to the exhaust flue gas.</li> <li>Simple structure and low initial cost</li> <li>low treatment efficiency</li> </ul>
Reagent	Ca(OH) <sub>2</sub> , CaCO <sub>3</sub> , NaOH, Mg(OH) <sub>2</sub>	Ca(OH) <sub>2</sub> NaCO <sub>3</sub> NaHCO <sub>3</sub>	Ca(OH) <sub>2</sub> NaHCO <sub>3</sub>
Selection		Our Technology	WDUFO.

22





### **Dioxin System**

#### **Activated Carbon**




Figure 1: Activated carbon structure - schematic.






Figure 2: Activated carbon structure – SEM pictures.

- Activated Carbon is the most effective adsorbent.
- Activated Carbon has a porous structure of about 1500 m<sup>2</sup>/ gm.

# System Configuration



#### **Mechanism of Reduction**











### **Reference Plant**










# Plant Concept (NAJU WTE, Korea)

- Plant Capacity: 19.6MWe
- Main Equipment
  - CFBC Boiler (Hansol SeenTec; Korea), Condensing Turbine (KHI; Japan)










# **Design - Plan**










### **Design - Section**




MBT ROOM TYPICAL SECTION







# **Design - Section**











# **Design - Section**














### **Pre-Treatment System**


- The Pre-Treatment system is required for the application of the CFBC Boiler which comprises of the several kinds of mechanical sorting, for instance, magnetic separation, density separation along with the manual pick-up of the recyclable materials.
- The Pre-Treatment system should be designed and selected according to the physical characteristics of the MSW in the course of basic design.
- It must do so in order to
  - Reduce the wastes volume; or
  - Reduce its hazardous nature; or
  - Improvement of Fuel Properties: Calorific Value/Segregation of Combustibles
  - Facilitate its handling; or
  - Recovery of the Recyclable Materials







# **Typical Pre-Treatment System**











### **Pre-Treatment System Process**




# **Boiler System – CFBC**





# Flue Gas Treatment System









### **Steam Turbine Generator**


















### **DCS**



# **Switch Yard**










### **Location for Sanggok WTE Plant**



42

## **Overview for Sanggok WTE Plant**



# **Pre-Treatment Facility**









# **Boiler, Turbine Building**










# **Project Execution Strategy**





## **Project Structure**




PM: Project Management SI: System Integration







### **PPP & FDI Scheme**



# **Project Overall Time Schedule**

#	Work Activity	Duration	Scope	Remark
1	MOA Letter	1 mon	GoV	
2	Deed of Special Purpose Company Establishment	1 mon	HEIP HOA/Hanvit Consortium	
3	Public Private Partnership Agreement	1 mon	GoV/SPC	
4	Perform Feasibility Study	5 mon	SPC	
5	Request WTE Power Plant Construction Permit	6 mon (TBD)	GoV	
6	Letter of Assignment Electricity Purchased to EVN	1 mon	GoV/EVN	
7	Power Purchase Agreement with EVN	3 mon	EVN/SPC	
8	Waste Supply Agreement	1 mon	GoV/SPC	
9	Insurance Agreement	2 mon	SPC	
10	Credit Agreement (Financial Closing)	3 mon	Lender/SPC	
11	Perform Basic Engineering for EPC Bidding	6 mon	SPC	
12	Bidding EPC and Contract	2 mon	SPC	
13	Start Construction (EPC)	35 mon	EPC	
14	Finish and Commercial Operation	25 years	SPC	

**GoV**: Government of Vietnam







# **Project Overall Time Schedule**


#	Work Activity		1	2	3	4	5	6	7	8	9	10	11	12	Зу	25y
1	MOA Letter	1										*				
2	Deed of SPC Establishment	1														
3	PPP Agreement	1														
4	Perform Feasibility Study & Request Permit	5														
5	Evaluation WTE Construction Permit	6														
6	Letter of Electricity Purchased to EVN	1														
7	PPA with EVN	3														
8	Waste Supply Agreement	1														
9	Insurance Agreement	2														
10	Credit Agreement (Financial Closing)	3														
11	Perform Basic Engineering for EPC Bidding	6														
12	Bidding EPC and Contract	2														
13	Start Construction (EPC)	35														
14	Finish and Commercial Operation	25y						; ;								







### **Licensing and Project Start Process**



F/S: Feasibility Study


**GoV**: Government of Vietnam







## **Project Organization**










# Milestone (35month)










# **Project Schedule**

	1st Year	2nd Year	3rd Year
Activity	1 2 3 4 5 6 7 8 9 10 11 12	13 14 15 16 17 18 19 20 21 22 23 24	25 26 27 28 29 30 31 32 33 34 35 36
Engineering & PMC			
Boiler & Incinerator System			
Flue Gas Treatment System			
Turbine & Accessory			
Pre-Treatment System			
BOP & Auxiliary System			
Electrical & I&C System			
Start-up & Commissioning			







### **Critical Path**


Duration for Major Equipment Manufacturing and Delivery

Boiler System : 15M (Including Incinerator)


Ash Handing System: 10M

Turbine & Generator: 15M

• DCS : 10M



### **O&M Organization & Staffing Plan**









### Scope of Supply -SPC

- Any activities for permitting and contact to authorities
- Studies and investigation, like soil, noise, grid study, etc.
- Prepare Waste (fuel), light fuel oil, sorbents, chemicals, water, electricity, etc., for commissioning and operation
- Plant operation and maintenance
- Any taxes, duties, levies in connection with the Project by the relevant tax authorities.
- Custom Clearance







### Scope of Supply – Hanvit Consortium

#### Basic & Detail Engineering

#### Equipment & Material Supply

- Reception and Waste Handling, Waste Pre-treatment System
- Boiler System
- Turbine System, Generator, Condenser, Water Seam cycle
- Flue Gas Treatment System and Ash Handling System
- Electrical, Instrumentation and Control
- Piping, Steel structure, Insulation, Painting, etc.
- Spare Parts for 1 years & Transportation

#### Construction

- Mechanical & Piping Work
- Electrical & Instrument Work
- Civil & Architecture Work

#### Commissioning & Performance Test

Supervision, Personnel training







### **Key Factor for Successful Project**

#### Financial Perspective Proposal

- The quantity(2,000tpd) and quality of waste should be guaranteed, so, after sorting we use 1,000 tpd as fuel for power generation
- Based on preliminary finical analysis, this project is a economically feeble projects, so, the tipping fee (\$12.00/ton) and Electricity Tariff (9.5 cents/kwh) should be increased for rate of inflation every two years.
- The electricity power tariff and purchasing should be guaranteed.

#### Critical Issue for Project

- The plant water shall be provided by GoI to the boundary of WTE plant.
- The design and construction task for transmission line are exclude from our budget, the switch yard should be connection point with EVN.
- SPC will performed licensing work for construction of MSW power plant, the active support of city are required
- The various warranty document are required to discuss with financial lender, the aggressive support of city for the warranty document are required







## **Risk Analysis**

#### Risk related to the project

- The project does not achieve the MSW calorific value, MSW Quantity, Minimum Annual Availability of Plant
- Conduct an extensive feasibility study to evaluate the associated risks

# Risk related to the procurement of critical equipment/material

- Critical equipment/material cannot be procured early stage.
- Prepare supplier short list

#### Risk related to public resistance

- The Success of Project lies in large part the public consensus
- > The Environmental Impact Assessment should be thoroughly carried out in advance.







# **Financial Analysis**





### **Plant Basic Data**

No.	ITEM	Data	Unit	Remark
1	Operation Year	25	Year	
2	WTE Plant Location	KCN Đình Vũ	-	
3	Land Fill Area	N20.827184, E106.768315	GPS	
4	Electricity Tariff	9.5	USCent/kwh	
5	Waste Tipping Fee	12.00	US\$/ton	
6	Waste Quantity	2,000	Ton/day	
7	Waste Composition	-	-	
8	Calorific Value	2,400	Kcal/kg	Assumed
9	Land Acquisition	\$20/m <sup>2</sup>	50 years	
10	Local Government Invest to SPC	N/A	-	воо
11	Cooperate Tax	20	%	
12	Estimate Interest Rate for Loan	7.0	%	
13	Estimate Discount Rate for Loan	12.0	%	
14	Average Worker Salary (1year)	5,000	US\$	







# **Financial Analysis**

**(25 Years)** 

ITEM	Value	Unit	Remark
Total Investment	\$171,085,000	USD	(for 3 Years)
Total Sales Electricity	\$411,694,535	USD	
<b>Total Waste Tipping Fee</b>	\$109,500,000	USD	
Fixed O&M Cost	\$6,600,360	USD	
Variable O&M Cost	\$94,465,573	USD	
Financial Cost (Debt + Interest)	\$231,948,489	USD	(for 10 Years)
Cooperate Tax	\$57,359,428	USD	
Net Income	\$161,358,357	USD	
Net Present Value(NPV)	\$480,583	USD	
Internal Rate of Return(IRR)	6.63%	%	







### **Reference Document**

- The Potential of Coprocessing Municipal Solid Waste MSW in Clinker Kilns to Cements; February 2016, Vietnam institute for building materials
- MRV designed for NAMAs in Waste Sector in Vietnam; Presented by: Anh Tien Do, Ph.D.; Vietnam Institute of Meteorology, Hydrology and Environment; August, 2016
- MRV designed for NAMAs in Waste Sector in Vietnam, Presented by: Anh Tien Do, Ph.D., Vietnam Institute of Meteorology, Hydrology and Environment; February, 2006
- Composition and Generation Rate of Household Solid Waste: Reuse and Recycling Ability A case study in District 1st, Ho Chi Minh City, Vietnam; Dieu T. M.; Department of Environmental Technology and Management; June, 2014
- Vietnam Environment Solid Waste; World Bank, MONRE, CIDA; 2004
- Study on the Industrial Waste Treatment and Waste-to-Energy Project in BINH DUONG Province, the Socialist Republic of Vietnam; February, 2013







### 2. Additional Discussion

<Pre><Precondition>

We use assumed data to answer your question. Real Project data can be identified after Feasibility Study and our assumed data can be changed.







### **Pre-treatment Process**

#### Assumption

Waste Transportation Truck : 10 ton Truck

Working Hour : 10 hour/day

The Pre-treatment Capacity : 95 ton/hour (24hour Operation)

**X Real Project data identified after Feasibility Study** 

#### Proposal (Preliminary)

- Waste Reception Process
- Truck coming in and coming out (including Washing Truck)
- Odor Problem
- Fuel Storage Concept (3day Storage capacity)








### **Waste Reception Process**

Waste Supplier : URENCO










### **Waste Truck**

Without Washing, Truck cannot out from the Plant.









### **Odor and Fuel Storage**

#### Areas that smell are in principle sealed

- Air curtains are installed to prevent the odor from discharging to the outside.
- Chemical solution cleaning tower will be installed where high concentrations of odors such as waste storage, leachate storage, and organic sorter areas
- In areas where low concentrations of odor in fuel storage and fueling facilities are install dust removal equipment and activated carbon odor removal tower

#### Fuel Storage Area

- The fuel reservoir is made of concrete pits, and the facility that stores the final fuel after processing the waste from the fueling plant
- Storage tank capacity is calculated based on the storage of 3 days of fuel capacity







## **Organic Material Treatment**

#### Basic principles of Waste disposal

- There is no way to completely dispose of the waste.
- Just the flammable wastes are used as fuel
- Low-calorific waste like organic waste that lowers power plant efficiency excludes fuel use.
- Food waste can be transported to sanitary landfill and then used as landfill gas, or it can be treated compost, feedstuff with separate facilities

#### Non-flammable waste estimated as follows

- Iron, nonferrous metal, valuable goods: sale
- Incombustibles, PVC: landfill
- Bed ash: landfill
- Fly ash: Consignment processing







### **Waste Treatment Process**

■ We estimate the quantity of waste without landfill survey, after Feasibility Study it will be fixed.










# **Waste Operational Planning**









### **Status in Korea for Organic Treatment**

|       | Treatment Method   | Plant | Remark |
|-------|--------------------|-------|--------|
| 1     | Feedstuff          | 173   |        |
| 2     | Compost            | 78    |        |
| 3     | Feedstuff, Compost | 3     |        |
| 4     | Incineration       | 54    |        |
| Total |                    | 308   |        |

by December 31, 2015





### **Organic Treatment Option**

#### Feedstuff: Re-Clean Co., Ltd.

- Location: 793, Heolleung-ro, Songpa-gu, Seoul, Korea
- Product : Raw Materials of Feedstuff
- Bio Oils: <1%</li>
- Tipping Fee: \$100/ton (Private Company)

#### Compost : Saenggok Organic Waste to Recycling Plant

- Location 76, Saenggok sandan-ro, Gangseo-gu, Busan, Korea
- Product : Compost
- Waste Water : Discharge to Sea after Treatment

74

Tipping Fee: \$55/ton (Busan City owned Company)

#### Separate Project Execution

Hanvit can support Hai Phong City with Separate Project








### **Plant Area**

#### **■** Total Area: 10 Ha

|   | Area Name                              | Width<br>(M) | Length<br>(M) | Area<br>(Ha) |
|---|--|--------------|---------------|--------------|
| 1 | Power Block                            | 100          | 180           | 1.80         |
| 2 | Pre-Treatment                          | 120          | 180           | 2.16         |
| 3 | Waste Receiving Storage                | 80           | 85            | 0.68         |
| 4 | Non-Combustible Return Storage         | 80           | 85            | 0.68         |
| 5 | Transportation Truck Parking & Washing | 140          | 180           | 2.52         |
| 6 | Miscellaneous Area                     | -            | -             | 2.00         |
|   | Total                                  |              |               | 9.84         |






### **Plant Area**

#### Site Plan Concept

- Two Gate for Entrance and Exit
- Separate receiving and return waste storage










# 3. Past Performance & Financial Status







### **Major Performance for HANVIT**





#### Plant Construction

| No | Project Name  | Year |
|----|---|------|
| 1  | GS Dangjin Combined Cycle Power Plant (CCPP) Commissioning                                      | 1999 |
| 2  | Secondary System Piping Insulation for KHNP Wolsong NPP Unit 3                                  | 2001 |
| 3  | K-Power Kwangyang LNG CCPP Commissioning  | 2004 |
| 4  | Electrical Power Facility Construction Work of Kori NPP In-House Power Outage Prevention System | 2005 |
| 5  | Developed the Asset Management System for all Korean Standard NPPs                              | 2009 |
| 6  | Korea Hydro & Nuclear Power (KHNP) Shin-Wolsong NPP Units 1&2 Commissioning                     | 2010 |
| 7  | KHNP Shin-Kori NPP Units 3&4 Commissioning  | 2011 |
| 8  | Developed the Asset Management System for Korea Western Power (KOWEPO) Taean TPP Units 9&10     | 2013 |
| 9  | Developed the Asset Management System for Korea Southern Power Samcheok TPP Units 1&2           | 2014 |
| 10 | Supervision for Piping Installation of KOWEPO Taean TPP Units 9&10                              | 2015 |







#### Plant Operation/Maintenance

| NO | Project Name  | Year   |
|----|---|--------|
| 1  | Developed the Operation Simulator for KHNP Korean Standard NPP                                  | 1999   |
| 2  | Plant Performance Analysis and Improvement Plan for KHNP Kori NPP Unit 1                        | 2000   |
| 3  | Developed the Operation Guidebook for Kori NPP Units 1&2  | 2000   |
| 4  | Plant Performance Analysis and Improvement Plan for Korea Midland Power Seoul TPP Unit 5        | 2001   |
| 5  | Plant Performance Analysis and Improvement Plan for KHNP Uljin NPP Unit 2                       | 2001   |
| 6  | Developed the Operation Guidebook for Uljin NPP Units 1&2                                       | 2001   |
| 7  | Test and Verification for KHNP Hanbit NPP Unit 1&2 Operation Simulator                          | 2004   |
| 8  | Nuclear Reactor and Steam Generator Maintenance for KHNP NPPs                                   | 2006 ~ |
| 9  | Test and Verification for Operation Simulator for KHNP APR (Advanced Power Reactor) 1400 NPPs   | 2007   |
| 10 | Motor Operated Valve and Air Operated Valve Inspection and Maintenance for KHNP NPPs            | 2008 ~ |
| 11 | Electrical System Test and Verification for KHNP Kori NPP Units 1,2,3&4                         | 2010   |
| 12 | Test and Verification for Operation Simulator for Barakah NPP in UAE                            | 2012   |
| 13 | Final Acceptance Test and Verification for Power Plant Electric System of Shoaiba II CCPP in SA | 2013   |
| 14 | Final Acceptance Test and Verification for Power Plant Electric System of Takoradi T2 in Ghana  | 2013   |
| 15 | Developed the Operation Simulator for CCPP (Combined Cycle Power Plant)                         | 2015   |
| 16 | Electrical System Test and Verification for Barakah NPP in UAE                                  | 2016   |





#### Engineering

| No | Project Name  | Year  |
|----|---|-------|
| 1  | Periodic Safety Review(PSR) for Kori NPP Unit 1 & Wolsong NPP Unit 1                                  | 2000  |
| 2  | Radioactive Environmental Qualification (EQ) for KHNP NPPs (Kori, Shin-Kori, Hanbit, Wolsong etc.)    | 2002~ |
| 3  | Soundness & Reliability Evaluation for Equipment/Component of KHNP Wolsong NPP Units 2,3 & 4          | 2002  |
| 4  | Heating & Ventilation Air Control System Design for KHNP Hanbit NPP Units 3&4                         | 2002  |
| 5  | Feasibility Study for Georgia 100 MW Hydro Power Plant  | 2006  |
| 6  | Developed the Configuration Management System for System-Integrated Modular Advanced Reactor          | 2007  |
| 7  | BOP (Balance of Power Plant) Equipment Procurement for KHNP Shin-Kori NPP Units 3&4                   | 2008  |
| 8  | Feasibility Study for Balephi Hydro Power Plant in Nepal  | 2008  |
| 9  | Electrical Equipment Procurement for Samcheok Green TPP Units 1&2                                     | 2014  |
| 10 | Preliminary Feasibility Study for 180MW Coal Fired Combined Heat Power Plant in Kazakhstan            | 2016  |
| 11 | Preliminary Feasibility Study for Simanggo II 90MW Hydro Plant in Indonesia                           | 2016  |
| 12 | Feasibility Study for Rehabilitation of Fenchuganj CCPP in Syhlet, Bangladesh                         | 2017  |
| 13 | Preliminary Feasibility Study for TPA Cipeucang Waste to Energy Plant in Tangerang Selatan, Indonesia | 2017  |







#### Quality Management/Control

| No | Project Name   | Year |
|----|--|------|
| 1  | Quality Surveillance for Construction and Equipment Manufacturing for Korea Radioactive Waste Agency (KORAD) Radioactive Waste Disposal Facility | 2007 |
| 2  | Quality Surveillance for Equipment Manufacturing for KHNP Shin-Uljin NPP Units 1&2   | 2010 |
| 3  | Quality Surveillance for Construction and Equipment Manufacturing for Barakah NPP in UAE   | 2012 |
| 4  | Quality Surveillance for Manufacturing & Replacement of Nuclear Steam Generator for Hanbit NPP Units 3&4   | 2015 |

#### Training and Education

| No | Project Name  | Year  |
|----|---|-------|
| 1  | Qualification and In-Service Training for Nuclear Quality Inspectors  | 2000~ |
| 2  | Qualification Training for Nuclear Quality Auditors/Lead Auditors   | 2000~ |
| 3  | Inspection and Diagnosis Training for Nuclear Facilities Maintenance  | 2000~ |
| 4  | Training on the Operation of a Nuclear Power Plant for Hyundai, Daewoo, Daelim, Samsung, Doosan, POSCO, and other corporations.   | 2005~ |
|    | Training on Nuclear Quality Assurance and Codes/Standards to DSK Engineering, SWI Valve, ENSCO, Geonwoo Lighting, Byeoksan ENG, Dowha General Engineering, and other corporations | 2008~ |
| 6  | Training on the Operation of a NPP for Guangdong Thermal Power Engineering Corporation of China   | 2008  |







#### Quality Assurance

| No | Project Name  | Year  |
|----|---|-------|
| 1  | Developed Nuclear Quality Assurance Optimization Program for KHNP                               | 2000  |
| 2  | Study on Alteration of Quality Class System for Operating Nuclear Power Plants                  | 2006  |
| 3  | Operation of Quality Management System of Korea Electric Power Research Institute (KEPRI)       | 2007~ |
| 4  | Consulting to DSK Engineering for Quality Assurance System Qualification and Registration       | 2008  |
| 5  | Consulting to SWI Inc. for the Registration as Qualified Valve Supplier to KHNP                 | 2008  |
| 6  | Consulting to Byeoksan Engineering for KEPIC (Korea Electric Power Industry Code) Qualification | 2010  |
| 7  | Consulting to Dowha General Engineering Co, for KEPIC Qualification                             | 2010  |
| 8  | Developed Q/A Program for Operation and Maintenance of Heavy Water Nuclear Power Plants         | 2012  |
| 9  | Developed KEPIC-MD (Material Standard) 2012 Annex   | 2012  |







#### Research and Development

| No | Project Name   | Year |
|----|--|------|
| 1  | Participated in Integral Reactor Research and Development                                    | 2002 |
| 2  | Development of Standardized Technology for Nuclear Power Plant In-service Test               | 2003 |
| 3  | Developed Pneumatic Valve Performance Test Equipment and Assessment System                   | 2005 |
| 4  | Development of a Automatic Flushing and Sludge Removal Facility for Nuclear Steam Generators | 2006 |
| 5  | Developed Combined Cycle Power Plant Operation Simulator                                     | 2015 |
| 6  | Technology Development to Convert Low Grade Coal into High Calorific Coal                    | 2017 |

#### Other Services

| NO | Project Name  | Year  |
|----|---|-------|
| 1  | Repair Works for Valves, Heat Exchangers, etc. for KHNP Nuclear Power Plants                    | 2000~ |
| 2  | Developed the Integrated Radioactivity Management System for Nuclear Power Plants               | 2001  |
| 3  | Assessment & Control of Radiation Exposure  | 2002~ |
| 4  | Radiation Protection System Improvement   | 2002~ |
| 5  | Providing Nuclear Technology Data/Documents of IAEA, WANO, INPO and EPRI for Corporate          | 2004~ |
| 6  | Radiation Protection Training   | 2004~ |
| 7  | Treatment of Radioactive Waste: Collection, Disposal, Shipping and Storage of Radioactive Waste | 2006~ |







### **Financial Statements - Hanvit**

Separate Documents





# **Major Performance for KDHEC**





| Project Name                                    | Client/<br>Location    | Plant Capacity                  | Work<br>Scope | Project<br>Period |
|---|------------------------|---------------------------------|---------------|-------------------|
| Daegu Woodchip Power Plant                      | KDHC                   | 3MW x 1 (Woodchip)<br>(9Gcal/h) | F/S, B, OE    | 2006~2009         |
| Naju Power Plant                                | KDHC/<br>Lotte E&C     | 20MW x 1 (RDF)<br>(40Gcal/h)    | F/S, B, D     | 2008~2017         |
| Donghae Biomass Power Plant                     | Lotte E&C              | 30MW x 1 (Wood pellet)          | Proposal      | 2010~2011         |
| POIC Biomass CHP Plant                          | STX HI/<br>Malaysia    | 25MW x 1 (PKS)                  | D             | 2010~2012         |
| Wonju Biomass Power Plant                       | Lotte E&C              | 10MW x 1 (Wood pellet)          | Proposal      | 2011              |
| Saemangum CFBC Power Plant                      | OCI                    | 151MW x 2(Coal+Tail Gas)        | F/S, B        | 2011~2013         |
| Gimcheon CFBC Power Plant                       | Kimcheon<br>Energy     | 59MW x 1(Coal)                  | OE            | 2011~2013         |
| Colombia Termo Ecopetrol Petcoke<br>Power Plant | Posco E&C/<br>Colombia | 360MW x 1, 240MW x 1 (Petcoke)  | Proposal      | 2012~2013         |
| Dangjin Biomass CFBC Power Plant                | GS EPS                 | 105MW x 1 (PKS+Coal)            | OE            | 2012~2015         |







| Project Name                                 | Client/<br>Location       | Plant Capacity                  | Work<br>Scope | Project<br>Period |
|--|---------------------------|---------------------------------|---------------|-------------------|
| Seakmoon Biomass CFBC Power Plant            | Seakmoon<br>Energy        | 40MW x 1 (Wood pellet)          | D             | 2013~2016         |
| Pocheon CFBC Power Plant                     | STX Energy                | 160MW x 1(Coal+Biomass)         | В             | 2013~2015         |
| Naepo SRF CFBC Power Plant                   | Lotte E&C                 | 33.7MW x 2(SRF)                 | B, D          | 2014~2018         |
| Venezuela PetCoke Thermal Power Plant        | Hyundai E&C/<br>Venezuela | 300MW x 7 (PetCoke)             | В             | 2015~2016         |
| Gunsan CFBC Power Plant                      | KOMIPO Bio<br>Energy      | 100MW x 2 (Wood Pellet)         | B, OE         | 2015~2020         |
| Poseung Biomass CFBC Power Plant             | Poseung<br>Green Power    | 43.2MW x 1 (Wood Pellet)        | OE            | 2015~2018         |
| Yeosu Biomass Boiler Power Plant             | Yeosu<br>Bioenergy        | 43.2MW x 1 (Wood Pellet & Chip) | B, D          | 2016~2019         |
| Busan Myung-Ji Biomass Boiler Power<br>Plant | Kolon Global              | 9.9MW x 1 (Wood Chip)           | B, D          | 2016~2018         |







| Project Name                                 | Client/<br>Location          | Plant Capacity<br>(Fuel) | Work<br>Scope | Project<br>Period |
|--|------------------------------|--------------------------|---------------|-------------------|
| Goseong Hai #1, #2 Coal Fired Power Plant    | Korea<br>South-East<br>Power | 1040MW x 2<br>(Coal)     | OE            | 2016~2021         |
| Gangneung Anin #1, #2 Coal Fired Power Plant | Korea<br>South-East<br>Power | 1040MW x 2<br>(Coal)     | OE            | 2016~2020         |







| Project Name           | Client/<br>Location | Plant Capacity<br>(Fuel)           | Work<br>Scope | Project<br>Period |
|------------------------|---------------------|------------------------------------|---------------|-------------------|
| Daegu CHP Plant        | KDHC                | 44MW x 1 (LSWR)<br>(275Gcal/h)     | F/S, B, OE    | 1993~1997         |
| CheongJu CHP Plant     | KDHC                | 44MW x 1 (LSWR)<br>(150Gcal/h)     | F/S, B, D, OE | 1994~2000         |
| Songpa CHP Plant       | KDHC                | 12MW x 1<br>(INC's STM, 136Gcal/h) | F/S, B, OE    | 1995~2000         |
| Yeongjong-Do CHP Plant | ННІ                 | 127MW x 1 (LNG)<br>(306Gcal/h)     | F/S, OE       | 1997~1999         |
| Ansan CHP Plant        | ASUDI               | 63MW x 1 (LSWR)<br>(306Gcal/h)     | F/S, B, OE    | 1998~2000         |
| Hwasung CHP Plant      | KDHC                | 515MW x 1 (LNG)<br>(601Gcal/h)     | F/S, B, D     | 2003~2007         |
| Songdo CHP Plant       | ITEC                | 200MW x 1 (LNG)<br>(376Gcal/h)     | F/S, B, D     | 2004~2009         |
| Paju CHP Plant         | KDHC                | 515MW x 1 (LNG)<br>(599Gcal/h)     | F/S, B, D     | 2004~2011         |
| Pangyo CHP Plant       | Lotte E&C           | 146MW x 1(LNG)<br>(326Gcal/h)      | F/S, B, D     | 2005~2010         |







| Project Name                       | Client/<br>Location   | Plant Capacity<br>(Fuel)       | Work<br>Scope | Project<br>Period |
|------------------------------------|-----------------------|--------------------------------|---------------|-------------------|
| Suwan CHP Plant                    | Suwan Energy          | 109MW x 1 (LNG)<br>(165Gcal/h) | F/S, B, OE    | 2006~2009         |
| Samsong CHP Plant                  | KDHC                  | 100MW x 1(LNG)<br>(303Gcal/h)  | F/S, B, D     | 2006~2011         |
| Homaesil CHP Plant                 | HUCES                 | 60MW x 1 (LNG)<br>(275Gcal/h)  | F/S, B        | 2007~2008         |
| Gwanggyo CHP Plant                 | KDHC                  | 141MW x 1(LNG)<br>(306Gcal/h)  | F/S, B, D     | 2007~2012         |
| Yangju CHP Plant                   | KECC                  | 560MW x 1 (LNG)<br>(460Gcal/h) | F/S, B, D     | 2007~2014         |
| Byulnae CHP Plant                  | Byulnae<br>Energy     | 107MW x 1 (LNG)<br>(240Gcal/h) | F/S, B, D     | 2007~2013         |
| Nuevo PEMEX Co-Gen power plant     | Samsung<br>ENG/Mexico | 300MW x 1 (LNG)                | Proposal      | 2008              |
| Hakha CHP Plant                    | SK E&C                | 37MW x 1 (LNG)<br>(130Gcal/h)  | F/S, B        | 2008~2010         |
| Therme's Combine Cycle Power Plant | GS E&C/<br>Brazil     | 400MW x 1 (LNG)                | Proposal      | 2009              |







| Project Name                           | Client/<br>Location | Plant Capacity<br>(Fuel)       | Work<br>Scope | Project<br>Period |
|--|---------------------|--------------------------------|---------------|-------------------|
| ChilcaUNO Combine Cycle Power Plant    | GS E&C/<br>Peru     | 270MW x 1 (LNG)                | Proposal      | 2009~2010         |
| Yangsan Sasong CHP Plant               | Gyeongnam<br>Energy | 120MW x 1(LNG)<br>(120Gcal/h)  | F/S, B        | 2009~2010         |
| Hanam Misa CHP Plant                   | SK E&S              | 350MW x 1(LNG)                 | F/S, B, OE    | 2009~2014         |
| Wirye CHP Plant                        | SK E&S              | 400MW x 1(LNG)                 | F/S, B, OE    | 2009~2016         |
| ILO Peaky Simple Cycle Power Plant     | Posco E&C/<br>Peru  | 200MW x 2 (LNG)                | Proposal      | 2010              |
| Daegu Innovation City CHP Plant        | Lotte E&C           | 400MW x 1 (LNG)<br>(276Gcal/h) | F/S, B, D     | 2010~2014         |
| ChilcaUNO Power Station Add-on Project | Posco ENG/<br>Peru  | 277MW x 1 (LNG)                | D             | 2010~2013         |
| Chuncheon CHP Plant                    | Posco E&C           | 500MW x 1 (LNG)<br>(400Gcal/h) | F/S, B        | 2011~2012         |







| Project Name                           | Client/<br>Location         | Plant Capacity<br>(Fuel)       | Work<br>Scope  | Project<br>Period |
|--|-----------------------------|--------------------------------|----------------|-------------------|
| Dangjin #5 Combine Cycle Power Plant   | GS EPS                      | 900MW x 1(LNG)                 | В              | 2012~2013         |
| Pyengtaek #2 Combine Cycle Power Plant | KEPCO E&C                   | 947MW x 1 (LNG)                | D              | 2012~2015         |
| Osan CHP Plant                         | KEPCO E&C                   | 400MW x 1 (LNG)<br>(200Gcal/h) | Proposal, B, D | 2012~2015         |
| Dongtan #2 CHP Plant                   | KDHC                        | 900MW x 1 (LNG)<br>(600Gcal/h) | F/S,B,D        | 2012~2017         |
| CIPREL IV Power Plant Add-on Project   | KEPCO E&C/<br>Cote d'Ivoire | 110MW x 1 (LNG)                | D              | 2013~2015         |
| Bismayah IPP-Simple Cycle Power Plant  | Hanwha ENC/<br>Iraq         | 110MW x 1 (LNG)                | Proposal, D    | 2013~2016         |
| Anyang CHP plant                       | GS Power                    | 964MW x 1 (LNG)<br>(550Gcal/h) | В              | 2014~2015         |
|  | GS E&C                      |                                | D              | 2015~2021         |







| Project Name                            | Client/<br>Location | Plant Capacity  | Work<br>Scope | Project<br>Period |
|---|---------------------|---|---------------|-------------------|
| Sangam DMC Project                      | KDHC                | Turbo Chiller: 1,500USRT x 7 Absorption Chiller: 1,500USRT x 7 Ice Storage: 12,600USRT                | B,D           | 2001~2006         |
| Sangam IT Center                        | KDHC                | Turbo Chiller: 810USRT x 4  | B,D           | 2006              |
| Garak/Mungjeong CES Power Plant         | KDHC                | Gas Engine : 1.4MW x 1 (LNG) (1.5Gcal/h)  | F/S, B        | 2006~2007         |
| South East Logistics Center CES Project | KDHC                | Turbo Chiller: 2,000USRT x 4<br>Absorption Chiller: 1,500USRT x 8                                     | B,D           | 2006~2009         |
| Goyang CES Project                      | KDHC                | Turbo Chiller: 2,000USRT x 2 Absorption Chiller: 1,000USRT x 4 Ice Storage: 32,700RT                  | B,D           | 2007~2010         |
| Sangam2 CES Power Plant                 | KDHC                | Gas Engine : 3MW x 2 (LNG) PLB : 8Gcal/h x 2  | F/S, B, D     | 2007~2010         |
| D-Cube CES Project                      | KDHC                | Turbo Chiller: 1,600USRT x 3, 500USRT x 1 Absorption Chiller: 1,200USRT x 4 Gas Engine: 9MW x 1 (LNG) | F/S, B,D      | 2008~2011         |
| Sangam DMC Extension Project            | KDHC                | Turbo Chiller: 1,500USRT x 7 Absorption Chiller: 800USRT x 7  | B,D           | 2013~2015         |







| Project Name                                | Client/<br>Location          | Plant Capacity | Work<br>Scope | Project<br>Period |
|---|------------------------------|----------------|---------------|-------------------|
| Suwon Homesil DH Plant Construction         | HUCES                        | 138Gcal/h      | Supervision   | 2011~2013         |
| POSCO #7,#8,#9 CCPP Construction            | Posco<br>Energy              | 1200MW x 1     | Supervision   | 2012~2015         |
| Danggin Biomass Power Plant Construction    | GS EPS                       | 105MW x 1      | Supervision   | 2013~2015         |
| Hwasung Hyangnam 2 DH Plant Construction    | HUCES                        | 68Gcal/h       | Supervision   | 2014~2015         |
| Goseong Hai #1, #2 Power Plant Construction | Korea<br>South-East<br>Power | 1040MW x 2     | Supervision   | 2016~2021         |







### **Financial Statements - KDHEC**

Separate Documents







### 感恩 Cảm ơn









### **Answer for FBC Boiler**

#### Why the FBC Type Boiler Operation Cost high?

- It is required Sand for fluidizing. (More efficiency)
  - The operation of Fan for fluidizing use additional Electricity.
- So, more Operation Cost than Grate type
- The operation cost for our project
  - O&M cost for FBC Boiler = \$100/ton/day
  - We use 1000ton/day as fuel
  - So,  $1000 \times $100 = $100,000/day$
  - This cost consider as O&M cost in our Financial Analysis
- Despite the FBC Boiler use higher O&M Cost, it generate more electricity and better benefit to business





